

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

Corporate Identity Number(CIN):U40109KA 1999SGC025521

☎ : 0831-2470560

Fax : 0831-2470560

E-mail : [eeetlssbgm@gmail.com](mailto:eeetlssbgm@gmail.com)



OFFICE OF THE  
EXECUTIVE ENGINEER(EL)  
TL & SS DIVISION  
KPTCL BELAGAVI

NO : 948/BGV/EEE/TL&SS/TA/24-25/ 899

Date : 27.05.2024

Encl :

To,

The Superintending Engineer (Ele)  
Tr. (W&M) Circle,  
KPTCL, Belagavi.

Sir,

Sub:Performance of Atlanta make 20MVA, 110/33-11KV power transformers at various 110KV stations in TL&SS Dvn, KPTCL Belagavi – Reg.

- Ref: 1) CEE/(T&P)/SEE-1/EE(T3)/AEET11/2024-25/919-22 dt.22.04.2024..  
2) BGM/AEE/Nodal/110KV/NN/24-25/171 dt.27.05.2024  
3) SDT/AEE/110KV/Nodal/24-25/114 dt. 27.05.2024  
4) GPB/AEE/110KV/Nodal/24-25/111 dt.27.05.2024  
5) AEE/ Nodal/MKH/110KV/24-25/ 80 dt.27.05.2024.

Inviting your kind attention to the above subject, following are the details of Atlanta make 20MVA, 110/33-11KV power transformers at various 110KV stations and performance is found to be satisfactory.

**Details :**

Sl No	Name of the station	Transformer details	Transformer SL No	Date of commission	Remarks
1	110KV Yaragatti	20MVA, 110/11KV	1472/50	25.10.2021	Performance of the transformers found to be satisfactory till date
2	110KV Katakol	20MVA, 110/11KV	1472/60	27.10.2021	
3	110KV Yadwad	20MVA, 110/11KV	1507/130	19.08.2022	
4	110KV Mamadapur	20MVA, 110/11KV	1507/170	22.08.2022	
5	110KV Mudalagi	20MVA, 110/11KV	1601/120	30.03.2023	
6	110KV Hirebagewadi	20MVA, 110/11KV	1601/30	06.02.2023	
7	110KV Nehrunagar	20MVA, 110/11KV	1323-220	01.03.2021	
8	110KV Nehrunagar	20MVA, 110/11KV	1601/190	31.03.2023	
9	110KV Uchagaon	20MVA, 110/33KV	1472-110	31.12.2021	
10	110KV Udyambag	20MVA, 110/33KV	1472/150	11.01.2022	

This is for your kind information and needful.

Yours Faithfully

Executive Engineer (Ele)  
TL&SS Dvn, KPTCL, Belagavi